



mna
LABORATUVARLARI

Notified Body Number: 2841



AB Tip İnceleme Sertifikası EU Type-Examination Certificate

Belge No / Certificate No

: 56100854

Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /

Certification Date / Certificate Validity Date

: 08.10.2025-08.10.2030

Belge Geçerlilik Tarihi / Document Validity Period

: 5 yıl / 5 years

Firma Unvanı ve Adresi /

Company Name and Address

: JEDX MEDCARE

Köysikuja 1, 01640 Vantaa, FINLAND

Marka / Model / Brand / Model

: JEDX FFP3

Direktifi / Directive

: 2016/425 REGULATION

Modülü/Kategori / Module / Category

: B MODÜLÜ/ KATEGORİ III

MODULE B / CATEGORY III

Teknik Değerlendirme Rapor No/

Technical Evaluation Report No

: 56100854

Ürün Tipi / Product Type:

- EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar - Parçacıklara karşı koruma amaçlı filtreli yarımskeler/ *Respiratory protective devices - Filtering half masks to protect against particles*

Ürünün Malzeme Bilgisi / Product Material Information: JEDX FFP3 model ürünleri kumaş, elastik kayış, burun klipsi ve filtre katmanı kullanılarak imal edilmiştir. / *JEDX FFP3 model products are manufactured using fabric, elastic strap, nose clip, filter layer.*

Karar Verici / Approver

Şirket Müdürü / General Manager



MNA Laboratuvarları San. Tic.Ltd .Şti
Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul
Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com

U-Frm-002/Rev.07/03.07.2024

This document has been signed electronically in accordance with the Electronic Signature Law No. 5070.

The document can be checked at <https://www.mnalab.com/en/sertifika-sorgula>




To certify the PPE product at Category III level, C2 or D module is accompanied by applying one of the conformity assessment methods along with the EU Type Examination (Module B).

Model : JEDX FFP3

| PPE SPECIFICATION | PERFORMANCE LEVELS |
|-----------------------------|--------------------|
| Classification | FFP3 |
| Reusable / Single Shift Use | NR |

PPE produced as a single unit to fit an individual user, all the necessary instructions for manufacturing such PPE on the basis of the approved basic model:

| MARKING |
|--|
| MANUFACTURER: JEDX MEDCARE PPE TYPE: - EN 149:2001+ A1:2009 Respiratory protective devices - Filtering half masks to protect against particles MODEL: JEDX FFP3 PRODUCT SIZE: Standard sized PICTOGRAM AND PERFORMANCE LEVELS: EN 149:2001+ A1:2009 FFP3 NR      2841 Or Condition of Storage |

MNA LABORATORIES SAN. TIC. LTD. ŞTİ declares that the above-mentioned product meets the requirements of the directive according to the EU Directive 2016/425, the safety of the product is covered by the conditions and use specified in this certificate and in the technical file.

MNA Laboratuvarları San. Tic.Ltd .Şti

Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul
Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com

PRODUCT PICTURES



JEDX FFP3

DOCUMENTS IN THE TECHNICAL FILE

- Test Reports
- Technical Report

Report No : 56100854

Report Date : 08.10.2025

Application No : 56100854

1. COMPANY INFORMATION:

JEDX MEDCARE
Köysikuja 1, 01640 Vantaa, FINLAND

2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection filter material.

3. PPE TYPE IDENTIFICATION

EN 149:2001+A1:2009 Respiratory protective devices – Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES



JEDX FFP3

5. PPE DIMENSIONS:

JEDX FFP3 model has been found to be produced using standard sizes.

6. PPE PRODUCT MATERIAL INFORMATION:

The mask is made of elastic strap, nonwoven fabric on the outer and inner layers and filter material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.

8. ANALYSIS EVALUATION AND MARKING:

EN 149:2001 +A1:2009

| TESTS | PARAMETER | PERFORMANCE LEVELS | | | RESULTS | PERFORMANCE LEVELS | EVALUATION |
|----------------------------|---|--------------------|------|------|----------------|--------------------|----------------|
| | | FFP1 | FFP2 | FFP3 | | | |
| Part 7.3 Visual inspection | Shall also the marking and the information supplied by the manufacturer | | | | Appropriate | - | PASS |
| Banned Azo Dyes | < 30 mg/kg | | | | Not applicable | - | Not applicable |

| | | | | |
|---------------------------------------|---|----------------|---|----------------|
| Part 7.4 Packaging | Particle filtering half mask shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use. | Appropriate | - | PASS |
| Part 7.5 Material | When conditioned in accordance 8.3.1 & 8.3.2 the particle filter half mask shall not collapse. | Appropriate | - | PASS |
| Part 7.6 Cleaning and disinfecting | After cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class. | Not applicable | - | Not applicable |
| Part 7.7 Practical performance | No negative comments should be made by the test subject regarding any of the criteria evaluated. | Appropriate | - | PASS |
| Part 7.8 Finish of parts | Parts of the device likely to come into contact with the wearer shall have no sharp edge or burrs. | Appropriate | - | PASS |

| TESTS | PARAMETER | PERFORMANCE LEVELS | | | RESULTS | PERFORMANCE LEVELS | EVALUATION |
|------------------------------------|---|--------------------|------|------|---------------------|--------------------|------------|
| | | FFP1 | FFP2 | FFP3 | | | |
| Part 7.9.1 Total inward leakage | At least 46 out of the 50 individual exercise result | ≤25 | ≤11 | ≤5 | See the table below | FFP3 | PASS |
| | At least 8 out of the 10 individual wearer arithmetic means | ≤22 | ≤8 | ≤2 | See the table below | FFP3 | PASS |

| Total Inward Leakage (%) | | | | | | |
|---|--|------------|------------|------------|------------|------------|
| | | Exercise 1 | Exercise 2 | Exercise 3 | Exercise 4 | Exercise 5 |
| Subject 1 (As received) | | 1,5 | 0,8 | 0,9 | 1,3 | 1,9 |
| Subject 2 (As received) | | 0,6 | 0,3 | 1,5 | 1,1 | 2,5 |
| Subject 3 (As received) | | 0,7 | 0,5 | 1,6 | 0,9 | 1,6 |
| Subject 4 (As received) | | 1,1 | 1,7 | 0,3 | 0,8 | 1,7 |
| Subject 5 (As received) | | 0,8 | 1,9 | 1,6 | 0,7 | 0,7 |
| Subject 6 (After temperature conditioning) | | 0,9 | 0,5 | 0,9 | 0,4 | 2,4 |
| Subject 7 (After temperature conditioning) | | 1,2 | 2,4 | 1,2 | 3,4 | 1,2 |
| Subject 8 (After temperature conditioning) | | 2,6 | 2,7 | 2,6 | 2,5 | 1,7 |
| Subject 9 (After temperature conditioning) | | 0,6 | 1,7 | 0,6 | 1,7 | 0,9 |
| Subject 10 (After temperature conditioning) | | 1,4 | 1,9 | 1,8 | 3,5 | 2,9 |
| | | Average | | | | |

Subject facial dimensions

| Subject | Face Length (mm) | Face Width (mm) | Face Depth (mm) | Mouth Width (mm) |
|---------|------------------|-----------------|-----------------|------------------|
| 1 | 133 | 132 | 132 | 65 |
| 2 | 125 | 144 | 116 | 67 |
| 3 | 126 | 135 | 124 | 75 |
| 4 | 123 | 133 | 134 | 74 |
| 5 | 117 | 135 | 122 | 73 |
| 6 | 122 | 142 | 133 | 66 |
| 7 | 113 | 132 | 114 | 75 |
| 8 | 135 | 123 | 123 | 65 |
| 9 | 122 | 135 | 133 | 74 |
| 10 | 135 | 142 | 125 | 83 |

| TESTS | PARAMETER | PERFORMANCE LEVELS | | | RESULTS | PERFORMANCE LEVELS | EVALUATION |
|--|--|--------------------|------|------|------------------------|--------------------|------------|
| | | FFP1 | FFP2 | FFP3 | | | |
| Part 7.9.2 Penetration of filter material | Sodium chloride, 95 L/min %, max | % 20 | % 6 | % 1 | See the table below | FFP3 | PASS |
| | Paraffin oil, 95 L/min %, max | % 20 | % 6 | % 1 | See the table below | FFP3 | PASS |

| Penetration of filter material | | Sodium Chloride (%) | Paraffin Oil (%) |
|--|--|---------------------|------------------|
| As received | | 0,2 | 0,3 |
| As received | | 0,2 | 0,3 |
| As received | | 0,2 | 0,2 |
| After the simulated wearing treatment | | 0,3 | 0,3 |
| After the simulated wearing treatment | | 0,2 | 0,3 |
| After the simulated wearing treatment | | 0,2 | 0,2 |
| Mechanical strength and temperature conditioning | | 0,3 | 0,4 |
| Mechanical strength and temperature conditioning | | 0,3 | 0,3 |
| Mechanical strength and temperature conditioning | | 0,2 | 0,4 |

| TESTS | PARAMETER | PERFORMANCE LEVELS | | | RESULTS | PERFORMANCE LEVELS | EVALUATION |
|--|---|--------------------|------|------|----------------------|--------------------|----------------|
| | | FFP1 | FFP2 | FFP3 | | | |
| Part 7.10 Compatibility with skin | Materials shall not be known to be likely to cause irritation or any other adverse effect to health | | | | Appropriate | - | PASS |
| Part 7.11 Flammability | Mask shall not burn or not to continue to burn for more than 5 s | | | | Flame not seen | - | PASS |
| Part 7.12 Carbondioxide content of the inhalation air | Shall not exceed an average of % 1 | | | | 0,66 0,70 0,63 | - | PASS |
| Part 7.13 Head harness | It can be donned and removed easily | | | | Appropriate | - | PASS |
| Part 7.14 Field of vision | The field of vision shall acceptable in practical performance test. | | | | Appropriate | - | PASS |
| Part 7.15 Exhalation valve(s) | It shall withstand axially a tensile force of 10 N apply for 10 s. If fitted, shall continue to operate correctly after a continuous exhalation flow of 300 L/min over a period of 30 s. | | | | Not applicable | - | Not applicable |

| TESTS | PARAMETER | PERFORMANCE LEVELS | | | RESULTS | PERFORMANCE LEVELS | EVALUATION |
|--------------------------------------|------------------------|--------------------|-------------|-------------|------------------------|--------------------|------------|
| | | FFP1 | FFP2 | FFP3 | | | |
| Part 7.16 Breathing Resistance | Inhalation 30L/min | 0,6 mbar | 0,7 mbar | 1,0 mbar | See the table below | FFP3 | PASS |
| | Inhalation 95L/min | 2,1 mbar | 2,4 mbar | 3,0 mbar | See the table below | FFP3 | PASS |
| | Exhalation 160L/min | 3,0 mbar | 3,0 mbar | 3,0 mbar | See the table below | FFP3 | PASS |

| Breathing Resistance (mbar) | | Inhalation 30L/min | Inhalation 95L/min |
|-----------------------------|--|--------------------|--------------------|
| As received | | 0,5 | 1,7 |
| As received | | 0,5 | 1,7 |
| As received | | 0,4 | 1,6 |

| | | |
|---------------------------------------|-----|-----|
| After temperature conditioning | 0,5 | 1,6 |
| After temperature conditioning | 0,5 | 1,6 |
| After temperature conditioning | 0,4 | 1,5 |
| After the simulated wearing treatment | 0,5 | 1,6 |
| After the simulated wearing treatment | 0,5 | 1,7 |
| After the simulated wearing treatment | 0,5 | 1,7 |
| After the flow conditioning | - | - |
| After the flow conditioning | - | - |
| After the flow conditioning | - | - |

| Breathing | Resistance 160L/min (mbar) | Facing directly ahead | Facing vertically upwards | Facing vertically downwards | Lying on the left side | Lying on the right side |
|---------------------------------------|----------------------------|-----------------------|---------------------------|-----------------------------|------------------------|-------------------------|
| As received | 2,8 | 2,7 | 2,7 | 2,7 | 2,7 | 2,7 |
| As received | 2,7 | 2,7 | 2,7 | 2,8 | 2,8 | 2,8 |
| As received | 2,7 | 2,8 | 2,8 | 2,7 | 2,7 | 2,7 |
| After temperature conditioning | 2,7 | 2,7 | 2,8 | 2,7 | 2,7 | 2,7 |
| After temperature conditioning | 2,7 | 2,8 | 2,7 | 2,8 | 2,7 | 2,7 |
| After temperature conditioning | 2,7 | 2,7 | 2,7 | 2,7 | 2,7 | 2,7 |
| After the simulated wearing treatment | 2,7 | 2,8 | 2,7 | 2,8 | 2,8 | 2,8 |
| After the simulated wearing treatment | 2,8 | 2,8 | 2,8 | 2,7 | 2,7 | 2,7 |
| After the simulated wearing treatment | 2,8 | 2,7 | 2,7 | 2,8 | 2,8 | 2,7 |
| After the flow conditioning | - | - | - | - | - | - |
| After the flow conditioning | - | - | - | - | - | - |
| After the flow conditioning | - | - | - | - | - | - |

| TESTS | PARAMETER | PERFORMANCE LEVELS | | | RESULTS | PERFORMANCE LEVELS | EVALUATION |
|-------------------------------|---|--------------------|--------|----------------|----------------|--------------------|----------------|
| | | FFP1 | FFP2 | FFP3 | | | |
| Part 7.17 Clogging | After clogging the inhalation resistances shall not exceed. (valved) | 4 mbar | 5 mbar | 7 mbar | Not applicable | - | Not applicable |
| | The exhalation resistance shall not exceed 3 mbar at 160 L/ min continuous flow. (valved) | | | Not applicable | | - | Not applicable |
| | After clogging the inhalation and exhalation resistances shall not exceed. (valveless) | 3 mbar | 4 mbar | 5 mbar | Not applicable | - | Not applicable |
| Part 7.18 Demountable part | All demountable parts (if fitted) shall be readily connected and secured were possible by hand. | | | Not applicable | | - | Not applicable |
| Part 9 Marking | The packaging information shall be clearly and durably marked on the smallest commercially available packaging or legible through it if the packaging is transparent. | | | Appropriate | | - | PASS |

9. ATTACHMENTS

- Test Reports (M-2022-0665)

CONTROLLER : _____

MNA LABORATORY
ANALYSIS REPORT

| | | | |
|--------------------------|----------------------------|--------------|------|
| Report Nu. : M-2022-0665 | Date : 2022-09-19 16:35:38 | Page : 1 / 5 | Rev: |
|--------------------------|----------------------------|--------------|------|

| | |
|------------------------|--|
| Purpose of Analysis | : Special request |
| Sample Send Org. | : SJT-Investment Group Oy / JedX Medcare |
| Address | : Köysikuja 1, 01640 Vntaa, Finland |
| Sample Acceptance Date | : 2022-08-15 00:16:52 |
| Analysis Date | : 2022-08-15 13:37:24 |
| Sample Quantity | : 120 Pieces |
| Sample Description | : JEDX FFP3 |
| Other informations | : |

Flammability

| Tests | Analysis result | Limit Value | Method | Evaluation | Physical Condition |
|--------------|------------------|---|------------|------------|--------------------|
| Flammability | Check the table. | Shall not burn for more than 5 sec after removal from the flame | EN 13274-4 | PASS | - |

Penetration Of Filter Material

| Tests | Analysis result | Limit Value | Method | Evaluation | Physical Condition |
|--------------------------------|------------------|--------------------------|------------------------------------|-------------|--------------------|
| Penetration Of Filter Material | Check the table. | FFP1≤20 FFP2≤6 FFP3≤1 | EN 149+A1 Part 8.11, EN 13274-7 | PASS (FFP3) | - |

| | Sodium Chloride (%) | Paraffin Oil (%) |
|---|---------------------|------------------|
| As received 1 | 0,2 | 0,3 |
| As received 2 | 0,2 | 0,3 |
| As received 3 | 0,2 | 0,2 |
| After the simulated wearing treatment 1 | 0,3 | 0,3 |
| After the simulated wearing treatment 2 | 0,2 | 0,3 |
| After the simulated wearing treatment 3 | 0,2 | 0,2 |
| Mechanical strength and temperature conditioning (120 mg) 1 | 0,3 | 0,4 |
| Mechanical strength and temperature conditioning (120 mg) 2 | 0,3 | 0,3 |
| Mechanical strength and temperature conditioning (120 mg) 3 | 0,2 | 0,4 |

MNA LABORATORY
ANALYSIS REPORT

| | | | |
|--------------------------|----------------------------|--------------|------|
| Report Nu. : M-2022-0665 | Date : 2022-09-19 16:35:38 | Page : 2 / 5 | Rev: |
|--------------------------|----------------------------|--------------|------|

Carbon Dioxide Content Of The Inhalation Air

| Tests | Analysis result | Limit Value | Method | Evaluation | Physical Condition |
|---|------------------|-------------|--------------------|-------------|--------------------|
| Carbon Dioxide Content Of The Inhalation Air | Check the table. | Maximum %1 | EN 149+A1 Part 8.7 | PASS (FFP3) | - |

| | |
|----------|---------|
| | CO2 (%) |
| Sample 1 | 0,66 |
| Sample 2 | 0,70 |
| Sample 3 | 0,63 |

Carbon Dioxide Content Of The Inhalation Air

| Tests | Analysis result | Limit Value | Method | Evaluation | Physical Condition |
|---|------------------|-------------|--------------------|-------------|--------------------|
| Carbon Dioxide Content Of The Inhalation Air | Check the table. | Maximum %1 | EN 149+A1 Part 8.7 | PASS (FFP3) | - |

| | |
|----------|---------|
| | CO2 (%) |
| Sample 1 | 0,66 |
| Sample 2 | 0,70 |
| Sample 3 | 0,63 |

Total Inward Leakage

| Tests | Analysis result | Limit Value | Method | Evaluation | Physical Condition |
|-----------------------------|------------------|-----------------------|--------------------|-------------|--------------------|
| Total Inward Leakage | Check the table. | See the limits table. | EN 149+A1 Part 8.5 | PASS (FFP3) | - |

| | | |
|------|--|---|
| | At least 46 out of the 50 individual exercise result shall be not greater than | At least 8 out of the 10 individual wearer arithmetic means shall be not greater than |
| FFP1 | ≤25 | ≤22 |
| FFP2 | ≤11 | ≤8 |
| FFP3 | ≤5 | ≤2 |

| | Exercise 1 | Exercise 2 | Exercise 3 | Exercise 4 | Exercise 5 | Average |
|--|------------|------------|------------|------------|------------|---------|
| | | | | | | |

MNA LABORATORY
ANALYSIS REPORT

| Report Nu. : M-2022-0665 | | Date : 2022-09-19 16:35:38 | | Page : 3 / 5 | | Rev: |
|---|-----|----------------------------|-----|--------------|-----|------|
| Subject 1 (As received) | 1,5 | 0,8 | 0,9 | 1,3 | 1,9 | 1,3 |
| Subject 2 (As received) | 0,6 | 0,3 | 1,5 | 1,1 | 2,5 | 1,2 |
| Subject 3 (As received) | 0,7 | 0,5 | 1,6 | 0,9 | 1,6 | 1,1 |
| Subject 4 (As received) | 1,1 | 1,7 | 0,3 | 0,8 | 1,7 | 1,1 |
| Subject 5 (As received) | 0,8 | 1,9 | 1,6 | 0,7 | 0,7 | 1,1 |
| Subject 6 (After temperature conditioning) | 0,9 | 0,5 | 0,9 | 0,4 | 2,4 | 1,0 |
| Subject 7 (After temperature conditioning) | 1,2 | 2,4 | 1,2 | 3,4 | 1,2 | 1,9 |
| Subject 8 (After temperature conditioning) | 2,6 | 2,7 | 2,6 | 2,6 | 2,5 | 1,7 |
| Subject 9 (After temperature conditioning) | 0,6 | 1,7 | 0,6 | 1,7 | 0,9 | 1,1 |
| Subject 10 (After temperature conditioning) | 1,4 | 1,9 | 1,8 | 3,5 | 2,9 | 2,3 |

Breathing Resistance

| Tests | Analysis result | Limit Value | Method | Evaluation | Physical Condition |
|----------------------|------------------|-----------------------|--------------------|-------------|--------------------|
| Breathing Resistance | Check the table. | See the limits table. | EN 149+A1 Part 8.9 | PASS (FFP3) | - |

| Classification | 30 L/min max basınç (mbar) | 95 L/min max basınç (mbar) | 160 L/min max basınç (mbar) |
|----------------|----------------------------|----------------------------|-----------------------------|
| FFP1 | 0,6 | 2,1 | 3,0 |
| FFP2 | 0,7 | 2,4 | 3,0 |
| FFP3 | 1,0 | 3,0 | 3,0 |

| Inhalation | 30 L/min | 95 L/min |
|----------------------------------|----------|----------|
| As received 1 | 0,5 | 1,7 |
| As received 2 | 0,5 | 1,7 |
| As received 3 | 0,4 | 1,6 |
| After temperature conditioning 1 | 0,5 | 1,6 |
| After temperature conditioning 2 | 0,5 | 1,6 |

MNA LABORATORY
ANALYSIS REPORT

| | | | |
|--------------------------|----------------------------|--------------|------|
| Report Nu. : M-2022-0665 | Date : 2022-09-19 16:35:38 | Page : 4 / 5 | Rev: |
|--------------------------|----------------------------|--------------|------|

| | | |
|---|-----|-----|
| After temperature conditioning 3 | 0,4 | 1,5 |
| After the simulated wearing treatment 1 | 0,5 | 1,6 |
| After the simulated wearing treatment 2 | 0,5 | 1,7 |
| After the simulated wearing treatment 3 | 0,5 | 1,7 |
| After the flow conditioning 1 | - | - |
| After the flow conditioning 2 | - | - |
| After the flow conditioning 3 | | |

| Exhalation 160L/min | Facing directly ahead | Facing vertically upwards | Facing vertically downwards | Lying on the left side | Lying on the right side |
|---|-----------------------|---------------------------|-----------------------------|------------------------|-------------------------|
| As received 1 | 2,8 | 2,7 | 2,7 | 2,7 | 2,7 |
| As received 2 | 2,7 | 2,7 | 2,7 | 2,8 | 2,8 |
| As received 3 | 2,7 | 2,8 | 2,8 | 2,7 | 2,7 |
| After temperature conditioning 1 | 2,7 | 2,7 | 2,8 | 2,7 | 2,7 |
| After temperature conditioning 2 | 2,7 | 2,8 | 2,8 | 2,8 | 2,7 |
| After temperature conditioning 3 | 2,7 | 2,7 | 2,7 | 2,7 | 2,7 |
| After the simulated wearing treatment 1 | 2,7 | 2,8 | 2,7 | 2,8 | 2,8 |
| After the simulated wearing treatment 2 | 2,8 | 2,8 | 2,8 | 2,7 | 2,7 |
| After the simulated wearing treatment 3 | 2,8 | 2,7 | 2,7 | 2,8 | 2,7 |
| After the flow conditioning 1 | - | - | - | - | - |
| After the flow conditioning 2 | - | - | - | - | - |
| After the flow conditioning 3 | | | | | |

MNA LABORATORY
ANALYSIS REPORT

Report Nu. : M-2022-0665

Date : 2022-09-19 16:35:38

Page : 5 / 5

Rev:

Operating as a test laboratory, MNA Laboratories is accredited by TÜRKAK according to AB-1183-T and TS_EN_ISO/IEC_17025:2017 standards has been done. A multilateral agreement with the European Accreditation Association (EA) on the recognition of the Turkish Accreditation Agency (TÜRKAK) test reports and It has signed a mutual recognition agreement with the International Laboratory Accreditation Association (ILAC).

*The analysis is within the scope of accreditation.

Note :

1. No part of this analysis report may be used alone or separately and may be partially copied or reproduced without the written permission of the laboratory. It cannot be reproduced, used by third parties or as a means of advertising.
2. Analysis results are valid for the sample sent and analyzed by the company/institution/individual to MNA Laboratories. represent the whole may not.
3. Unsigned and Unsealed reports are invalid.
4. This analysis report cannot be used in judicial-administrative proceedings and for advertising purposes.
5. Results are valid for the sample received.
6. A decision rule is a rule that determines how measurement uncertainty is to be taken into account when specifying compliance with a specified specification. TLM-052 Decision Rule According to the implementation instruction, the decision rule chosen in agreement with the customer will be applied if necessary.
7. Limit Values are determined by taking from analysis methods.
8. The laboratory is not responsible if the information provided by the CUSTOMER affects the validity of the results.
9. Test and / or measurement results, expanded measurement uncertainties (if any) and test methods are given in the following pages, which are the supplementary part of this certificate.
10. Water Repellency Determination Hydrostatic Pressure Determination TS ISO 811 (Hydrostatic Pressure Tester E / N: 53) Analysis, Seam Strength EN ISO 13965-2 (Strength Test Device E / N: 50) Analysis and resistance to liquid chemical permeation TS EN 659 -A1 Part 3.18 (Liquid Chemical Transfer Device E / N: 107) Analysis is carried out in the conditioning room and ISO 139 PART 3.2 conditions ($23 \pm 2^\circ\text{C}$ temperature and $50 \pm 4\%$ relative humidity) are applied for ambient conditions.

Selin Gergin

Sample Acceptance and Reporting Officer

2022-09-19 13:40:35

Erhan Üstünel

Laboratory Responsible

2022-09-19 16:11:58



VOLKAN AKIN

Laboratory Manager

2022-09-19 16:14:33

